




# Alternative Insitu software

SCF 9C03\_1 DST-SolTerm


vAConsult

G. van Amerongen


# Introduction



- Dynamic System Test (=DST)
  - System test for SDHW systems
    - EN 12976-2 and ISO 9459-5
- Two pieces of software needed:
  - Supplied only by 'InSitu software'
    - Fit program
    - Simulation model
  - Software not maintained anymore
- Project aim:
  - Find an alternative through Soltherm model
  - vAConsult & IGTE (ITW)




# Specifics on DST method






- Method described in standards:
  - ISO-9459-5: how to test
  - EN 12976-2: conditions (ref.'s)
- Test result is:
  - Fitted parameters for Insitu model
    - Insitu model is a specific simplified model
    - Developed for msDOS (fast coded)
- Working with new model:
  - Use existing measurements
  - Apply new fit program and simulation model
  - Gives fitted parameters for new simulation model
  - Base for annual performance calculations
- The new model is the SolTherm simulation model
  - Acceptable for EN 12977-2 (SN decision)
  - EPBD based
- The fit program is Excel 'Solver'
  - Freely accessible

Transition to new simulation model starts with fitting measurements to new model


# First results: promising



- First trial runs with existing DST measurements
  - Combi Soltherm & Solver is working
- Limited to hourly data:
  - Pre-heaters show good results
  - Solar Plus supplementary need some work.



## Next steps



- Issues with the SolTherm model
  - Model developed for heat demand and not volume demand
    - Added to the model
  - Model developed for hourly time step
    - Revision to smaller timestep in progress

- Future work
  - Test for solar plus with smaller timestep
  - Involve IGTE for more datasets
  - Test for annual performance prediction

PARAMETER IDENTIFICATION REQUEST									
Trial for alternative of Spurkl DST software									
Identified values									
	Min	Value	Max	Unit	Include:				
Acol;tot =	2	2.73	5	m2	Yes	Total collector area			
a1 =	3	5.792	6	W/(K.m2)	Yes	First order collector heatloss coefficient			
Hsol_loop =	1.5	3.802	5	W/K	Yes	Heatlosses collector loop piping			
Vsto =	100	235.7	350	Ltr	Yes	Total storage volume			
Hsto =	0.8	2.27	3	W/K	Yes	Tank heatloss rate			
Csto =	0.2	0.5	10	W/(m.K)	No	effective vertical heat conductivity			
InletPosition_Col	0.4	0.4773866	0.6	-	Yes	Tank inlet position from collector loop			
OutletPosition_Col	0	0	0.2	-	No	Tank outlet position from collector loop			
Hexch_Col	50	330.2	500	W/K	Yes	Collector heat exchanger heat transfer rate			
InletPosition_WHS	0	0.000165	0.3	-	Yes	Tank inlet position from water heating loop			
OutletPosition_WHS	0.6	0.8454607	1	-	Yes	Tank outlet position from water heating loop			
Hexch_WHS	0	0	3000	W/K	No	Water heating heat exchanger heat transfer rate			
InletPosition_Buh	0.81	0.9668162	1	-	No	Tank inlet position from Backup heater loop			
OutletPosition_Buh	0.3	0.3014618	0.8	-	No	Tank outlet position from Backup heater loop			
Hexch_Buh	0	31243.298	50000	W/K	No	Backup heater heat exchanger heat transfer rate			
Measured values				Fixed values					
	Value			Value				Run the solver	
System type:	SPS			a2	0	W/(K2.m2)			
SolLoc	H5	Loop location		IAM	1				
StoLoc	H5	Tank location		Mcol	0.02	kg/s	Proforma sum:	31876.88	Needed for Objective argument
TnkHeight	1800	mm		Eo	1.00	-	Objective:	0.3052	Argument needed to force call after recalc
Hexch_ColFlg	Yes	Yes/No		Tsto_init	15	oC	Solver cannot improve the current solution. All constraints are satisfied.		
Hexch_WHSFlg	No	Yes/No					Qhws;req =	-79.6	kWh
Hexch_BuhFlg	Yes	Yes/No					Qhws =	-78.8	kWh